



## DEVELOPMENT AND TESTING:

CBS MagVac retrofit circuit breakers are designed and tested to the latest ANSI/IEEE, IEC, and NETA standards.

Developed and tested within the guidelines provided in the following:

ANSI C37.09: Test Procedure for A/C High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis

ANSI C37.59: Standard Requirements for Conversion of Power Switchgear Equipment

IEC 62271-1: High-Voltage Switchgear and Control Gear; Common Specifications

IEC 62271-100: High-Voltage Switchgear and Control Gear; High-Voltage Alternating Current Circuit Breakers

NETA MTS-2011: Standard For Maintenance Testing Specification for Electrical Power Equipment and Systems

